


This is with refer to PO (21/D01/WOOPX/100080) received on dated 10.11.2020, In order to conduct Electrical Safety Audit of 'Sahyadri Super Speciality Hospital, Deccan'

Plot No. 30 C, Erandawane, Karve Road, Pune 411004 Ph. No 02067213000


The Audit is conducted & necessary data is collected by our site engineer Mr. Nilesh Randave on dated 9th of Dec 2020 in presence of concern person Mr. Akshy Amundkar.

The collected data list is as follows.

Sr. No.	Description
1	Brief about electrical infrastructure of Facility
2	Earthing Resistance Measurement
3	Switch Gear Validation
4	Cable Validation
5	Thermography of Major Panels
6	CEA 2010 Compliance check
7	Finding out Electrical Hazardous area
8	Recording of Main incomer supply for Power Quality Analysis
9	Briefing about audit findings to site Incharge


Stamp & Signature
14.12.2020.




11.12.2020.
For SAS Powertech Pvt. Ltd.