

Report on Power Quality Analysis

And

Energy Audit

Audit Conducted at
Leading IT Company
Hinjewadi Pune

Date of Audit
12th to 20th June 2013.

INDEX

| | |
|---|----|
| 1. Objective and the details of the equipment | 3 |
| 2. Executive summary savings and paybacks | 4 |
| 3. Description of electrical system | 6 |
| 4. Procedure followed during the recording | 7 |
| 5. Harmonic Mitigation requirements. | 8 |
| 6. Recorded current harmonics. | 9 |
| 7. Summary of recorded electrical Load on various feeders | 10 |
| 8. Total running KW Pie Chart. | 11 |
| 9. Floor Level Loading Pie Chart | 12 |
| 10. Summary of PQ parameters at floor level IT feeders. | 13 |
| 11. Abnormal earthing test results. | 19 |
| 12. Abnormal Lux Levels measured at few locations. | 20 |
| 13. Abnormal Infrared thermography test results. | 22 |
| 14. HVAC Energy audit – observations and recommendations | 43 |
| Note: Detail recorded data is arranged in separate appendix | |

Objective and the details of the equipment

Objective:

- 1) Study and understand electrical single line diagram of distribution network inside the premises.
- 2) Check and record electrical power quality pattern at all major feeders.
- 3) Study current harmonic contents starting from maximum upstream point / points on the single line diagram as per compliance requirements of IEEE 519 1992 standard
- 4) Measure and calculate working efficiency of all UPS systems and comment on possible savings.
- 5) Study historical energy consumption and tariff and comment on possible savings from cost of energy purchase point of view. (If applicable and possible)
- 6) Study and comment on reactive power compensation
- 7) Suggest remedies for harmonic mitigation and maintaining unity power factor
- 8) Undertake IR thermography to know thermal health of electrical distribution system.
- 9) Earthing audit to know health of electrical earthing throughout premises.
- 10) Demand Analysis of HVAC requirements, measurement of actual energy consumption by various HVAC systems, performance assessment of installed HVAC systems and recommendations to improve energy performance of these HVAC systems along with payback.
- 11) Recording energy consumption for illumination and survey of available illumination. Recommending energy saving options along with payback.
- 12) Present report on above data and analysis.

Details of Equipment Used:

| No | Name of the equipment | SR. No Model | Make | Use | Calibration Validity |
|----|-----------------------|-----------------|---------|----------------------------------|----------------------|
| 1 | Power Analyzer | 1212 5:8 ALM 35 | KRYKARD | Electrical Parameter Measurement | 27/2/2014 |
| 2 | Power Analyzer | 1212 5:8 ALM 35 | KRYKARD | Electrical Parameter Measurement | 27/2/2014 |
| 3 | Infrared Camera | Testo 875-2 | TESTO | Thermography | 18/8/2013 |
| 4 | Earth Tester | DECT-3 | MOTWANE | Earth Tester | 30/8/2013 |

Audit team


-----:

Mr. Narendra Duvedi, (Certified energy auditor)
Mr. Vijay Sonawane, Mr. Mandar Kolhatkar
Mr. Ranjit Deshmukh, Mr. Sunil Gogate (Certified energy auditor)
Mr. Ajit Gowande.

ABC : Mr Mohan Mulay and his team.

Certification:

Report Certified by:




Narendra R. Duvedi. (CEO -----)

B.E. Electrical and Certified Energy Auditor Reg No: EA 10859)


Executive Summary:

- 1) XYZ is IT setup working in owned premises. The present occupied area is about 204000 sq ft. Major source of energy at present is electricity available from MSEDCL. Average monthly consumption is about 350000Kwh. Setup avails all possible incentives in electricity bill and present per kWh rate is at its lowest and is around Rs. 6.5.
- 2) During audit, work area occupancy was around 1050. (Not considering auditorium) The energy consumption actually measured was 11530 Kwh in 22 hrs and 50 mins.
- 3) Current harmonic distortion compliance limit is 15% as per IEEE 519 1992, however present maximum distortion level is 12%, which is well within limit. Any time you decide to replace APFC capacitors here, you should replace them with detuned filters to avoid harmonic amplification.
- 4) Electrical power quality parameters for the power available to all critical loads are well within acceptable limits and the redundancy is also reasonably sufficient. Admin floor voltage harmonic distortion is slightly above 5%, which should be investigated.
- 5) Following Pie Chart shows contribution by different loads.



As can be seen from above 53% load is HVAC load and 46% load is UPS load.

- 6) About 200 KW load during night
- 7) The work station UPS configuration was earlier 5 x 200 KVA. Now the same is replaced with 3 x 200 KVA and the setup works at average efficiency of 85%. Data center load is supported by 2 x 200 KVA and also works at 85% efficiency. We recommend that these UPS systems could be replaced with modular systems and vertical redundancy to get flat 95% efficiency. This will save about 24KW running load and around Rs. 13.5 Lacs annually through energy saving alone.
- 8) Illumination Load is 44 KW and presently supported from workstation UPS output. This load may be transferred to Raw power to save another 8 KW. This translates to saving of Rs.4.5 Lacs annually. You may arrange different UPS / inverter for emergency light requirement.
- 9) HVAC demand analysis for against installed HVAC system shows that the total peak demand is 348 TR and installed capacity is 1360 TR at peak summer load. Following bar charts show area wise capacities. *(These calculations are done against actual occupancy during dates of audit. Separate calculations are available in the report which show demand against occupancy as per layout)*



10) Above charts show that installed capacities are very high compared to required capacities. Theoretically it is possible to switch off 2 out of every 3 VRV units. However practically one has to check the end results by assessing comfort levels while doing this. If this is done, there is possibility of saving around 300000 Kwh or Rs.20 Lacs at current tariff. This would also release VRV HVAC equipment of capacity around 800 Tr, which can be used elsewhere. Floor redesign using various ducting options is also feasible to achieve this saving and to release extra capacity.

11) If you can provide around 5000 sq ft roof top space, it is possible to install 40KW roof top grid connected PV solar generation, which will run in sync with transformer secondary in load sharing mode. The setup can generate about 200Kwh per day average throughout the year. This would yield net savings of about Rs. 4.75 Lacs per year for 1st five years.

Savings and payback at a glance

| Sr | Area | Investment Required in INR | Possible energy and other cost saving in INR per year | Payback in Years |
|--|------------------------------|----------------------------|---|-------------------|
| 1 | UPS efficiency increase | 8500000.00 | 3000000.00 * | 2.8 |
| 2 | VRV reconfiguration | NIL | 20,00,000.00 ** | 0 |
| 3 | Using Raw power for Lighting | NIL | 4,50,000.00 | 0 |
| | Total | 8500000.00 | 5450000.00 | 18 Months. |
| <ul style="list-style-type: none"> * Payback will reduce drastically if OLD UPS are auctioned rather than scrapped. Other costs include AMC, Scrap, Harmonic Filters etc. ** VRV reconfiguration will release 800 TR VRV equipment, which can be used elsewhere. Solar PV related figures are not presented above as the payback in this case also depends upon subsidies and Income tax rebates, which are not related to reduction in energy consumption. | | | | |

-----END OF SUMMARY-----

Description of energy distribution system

ABC Hinjewadi is a software development company located in large premises at Hinjewadi Pune, which is owned by them. ABC receives MSEDCL supply from a receiving station located just across the road. The HT supply is 22KV. The HT supply is received in ABB make RMU and distributed to two transformers. Transformers are rated at 1600KVA and work in either one working one standby or two working mode through suitable bus - coupler arrangement. The LT – AC thus available is further distributed to various utilities through distribution panels named MLTP 1 and MLTP 2. Critical IT load is divided into workstation – floor area load and DC load and is supported using separate UPS configurations. UPS configurations are as follows

- 1) 200KVA UPS X 5 of Chloride make (12pulse rectifier based), for Workstation area Load working in parallel redundant mode. (Installed in basement)
- 2) 200 KVA X 2 of Chloride make (12pulse rectifier based), working independently as dual power supply for Datacenter Load. (Installed on DC floor)

UPS output and floor area raw power is distributed using duplicated bus raisers for redundancy and tapped on each floor. Floor level redundancy is achieved through static switches located at strategic locations.

UPS output is distributed on floor as well as Server rooms through dedicated DBs. VRV ODU and TFA distribution is arranged on each floor through DBS in Galleries provided on respective floors.

Reactive power compensation is provided using capacitor panels in respective MLTP rooms with a provision to get them connected under any mode of bus coupler arrangement. Entire illumination load at present works on UPS output.

Electrical installation appears to be well maintained and in proper working condition. The buildings are not yet fully occupied and total electrical load is likely to increase beyond present level.

Procedure followed during the recording.

The company has work schedule of 12-15 hours a day and 5 days a week

The electrical parameter recording was done for 24 hours duration with High end Power Analyzer to know pattern of consumption throughout the day at strategic locations. Loads in further distribution were recorded for 10 min or for one full load cycle as applicable. After confirming the feeder wise consumption with total incomer consumption, the data was used to prepare energy Pie chart. This data was then analyzed during preparation of this report. Feeder wise Graphical representation of all recorded parameters is attached to this report as annexure, which can remain with you as record.

Simultaneous survey of panel wise earthing arrangement was carried out to know status of earthing.

Detail illumination audit was conducted at all work areas to know illumination levels.

IR Thermography was done for Main incomers, Sub -feeders and for UPS system to further sub-distribution. Loose Terminations were pointed out and suggestions about re-termination were given to concerned persons.

The facility is equipped with VRV HVAC systems for work area. PAC HVAC systems for DC area and ductable splits for UPS rooms and few isolated areas. A detail demand analysis was carried out for all these areas based on

- 1) Area drawings, known building parameters,
- 2) Measured occupancy
- 3) Measured equipment load.
- 4) Known usage schedules.

These requirements were compared with installed capacities of equipment and their present energy consumption.

Detail HVAC measurements along with thermography was carried out on all installed HVAC equipment to know their present status.

A report based on above data on HVAC system was prepared to know their energy performance and recommendations related to energy saving.

Harmonic Mitigation requirements.

IEEE519 1992 is an international standard followed worldwide for Harmonic mitigation between utility and consumer. Here the utility supply is available from MSEDCL. MSEDCL supply code 2005 will be applicable document for compliance. The clauses to be referred are 12.1 and 12.2. This standard requires that we should calculate a ratio I_{sc} / I_L , where I_{sc} is short circuit current of utility supply transformer and I_L is consumer's average load current for last 12 months. Once this ratio is known, a table in standard has to be referred to for deciding compliance limit.


| | |
|---|----------------|
| Client: ABC Hinjewadi | |
| Parameter | Value |
| MSEDCL Transformer Capacity MVA | 50.00 |
| MSEDCL Transformer % Impedance | 14.93 |
| Contract Demand KVA | 1500.00 |
| Max current as per contract demand on LT Side AMPS | 2000.12 |
| Max Load Current I_L Amps on LT Side AMPS | 1257.00 |
| HT System Voltage K Volts | 22.00 |
| LT System Voltage | 433.00 |
| Full Load current of MSEDCL Transformer Amps | 1312.20 |
| Short Circuit current of MSEDCL Transformer I_{sc} Amps | 8789.00 |
| Plant current as per contract demand on HT side | 39.37 |
| Plant Average load current on HT side | 24.74 |
| | |
| I_{sc} / I_L Ratio as per contract demand | 223.26 |
| I_{sc} / I_L Ratio as per Average Plant Current | 355.25 |

Table showing Current harmonics level compliance limits as per IEEE 519 – 1992


| Maximum harmonic current distortion in percentage of I_L for voltages less than 22KV. | | | | | | |
|---|-------|---------|---------|---------|---------|-------|
| Individual harmonic order (odd harmonics) | | | | | | |
| I_{sc}/I_L | <11h | 11=h<17 | 17=h<23 | 23=h<35 | 35=h<49 | TDD |
| <20* | 4.00 | 2.0 | 1.5 | 0.6 | 0.3 | 5.00 |
| 20<50 | 7.00 | 3.5 | 2.5 | 1.0 | 0.5 | 8.00 |
| 50<100 | 10.00 | 4.5 | 4.0 | 1.5 | 0.7 | 12.00 |
| 100<1000 | 12.00 | 5.5 | 5.00 | 2.0 | 1.0 | 15.00 |
| >1000 | 15.00 | 7.00 | 6.00 | 3.5 | 1.4 | 20.00 |
| Even harmonics are limited to 25% of odd harmonic limits above. | | | | | | |

As per above current harmonics compliance limit is 15% as the ratio is 223 or 355. The current harmonic distortion observed at main incomer is 12% max with capacitors ON. The same reduces to 7% when capacitors are OFF. This indicates amplification of harmonics due to resonance. The annual electricity bills show that Power factor is unity in every month and full P.F. Incentive is available. This situation needs to be checked whenever load increases. Further whenever these capacitors are to be replaced, they should be replaced with detuned harmonic filters to avoid current harmonic amplification.

Current Harmonics with capacitors ON




Current Harmonics with capacitors OFF



Above graphs indicate harmonic amplification, which will increase if more capacitors are added to correct power factor after increase in Load.

Summary of recorded running electrical load



Being a typical IT setup, computer load and requirement of conditioned power is almost stable during working hours. In this case distributed air conditioning is implemented using VRV – HVAC systems. At feeder / floor level these HVAC systems act as variable loads, however at PCC, their combined vector addition is a KW load which varies only 15%. So day time average is around 700KW, while night time average is 400KW.

KW Load at main LT incomer

| KW at Main feeders | Avg | Peak |
|---------------------------|---------|---------|
| Data Centre AC | 57.706 | |
| Data Centre UPS | 96.28 | 149.65 |
| Main UPS Panel + Lighting | 217.929 | 237.913 |
| Core-HVAC + Raw | 292.575 | 340.572 |
| Admin Panel | 4.259 | 8.273 |
| | 611.043 | 736.408 |

KWH Consumption during day of audit


| | Duration - 22:50 (h:min) | | |
|-----------|---------------------------|----------|----------|
| Date | | Time | Kwh |
| 12/6/2013 | Start | 11:20 AM | 1.13533 |
| 13/6/2013 | End | 10:11 AM | 11531.54 |
| | Total | | 11530.41 |

| Constant consumption day time Kwh | 1st slope KWh | | |
|-----------------------------------|---------------|----------|----------|
| Time | kwh | Time | kwh |
| 11:20 AM | 1.13533 | 5:47 PM | 4369.026 |
| 5:47 PM | 4369.026 | 10:00 PM | 6440.426 |
| KWh (6hrs 27Mins) | 4367.891 | | 2071.4 |


| Constant consumption night time Kwh | 2nd slope Kwh | | |
|-------------------------------------|---------------|----------|----------|
| Time | kwh | Time | kwh |
| 10:00 PM | 6440.427 | 7:20 AM | 10038.25 |
| 7:20 AM | 10038.247 | 10:11 AM | 11531.54 |
| KWh (9hrs 20 Mins) | 3597.8207 | | 1493.294 |

This matches to monthly consumption within +/- 10%. Out of 400KW working load during night, 150KW correspond to Data Center AC and Data center UPS, which will be ON as required by process. However it may be worthwhile to investigate remaining 250KW through various SOPs established for the process.

Typical Running KW load under different heads and their % to total running load. (Reference: above data recording)



Monthly KWH consumption during last year




Tariff Analysis:

| Month | Total bill paid | KWH recorded | Billed Demand KVA | Billed Power Factor | A | B | C | D | Net TOD | Demand Charges | Energy Charges | FAC | Max PF Incentive | P.F. Incentives | Final Rate Rs./Kwh |
|--------|-----------------|--------------|-------------------|---------------------|---------|---|---------|---------|----------|----------------|----------------|----------|------------------|-----------------|--------------------|
| May-13 | 2103334 | 339106 | 1018 | 1 | -173445 | 0 | 45046.4 | 54107.9 | -74290.7 | 193420 | 2146541 | -32927.2 | 156292 | 156292 | 6.202586 |
| Apr-13 | 2439764 | 387780 | 990 | 1 | -253800 | 0 | 44640 | 72534 | -136626 | 188100 | 2454647 | 84187.04 | 181322 | 181322 | 6.291618 |
| Mar-13 | 2255718 | 351160 | 834 | 1 | -244400 | 0 | 40960 | 64416 | -139024 | 158460 | 2222843 | 153281.3 | 167689 | 167689 | 6.42362 |
| Feb-13 | 1976661 | 301360 | 758 | 1 | -217350 | 0 | 34144 | 57354 | -125852 | 144020 | 1907609 | 174005.3 | 146985 | 146985 | 6.559134 |
| Jan-13 | 2150179 | 334060 | 758 | 1 | -242400 | 0 | 37104 | 63228 | -142068 | 144020 | 2114599 | 166996.6 | 159848 | 159848 | 6.436506 |
| Dec-12 | 2396600 | 344860 | 758 | 1 | -99780 | 0 | 38464 | 64900 | 3584 | 144020 | 2182964 | 217020.4 | 178331 | 178331 | 6.949488 |
| Nov-12 | 2529046 | 335660 | 792 | 1 | -97740 | 0 | 37200 | 62392 | 1852 | 150480 | 2124728 | 413734.5 | 188356 | 188356 | 7.534547 |
| Oct-12 | 2695274 | 372060 | 826 | 1 | -105060 | 0 | 42032 | 68508 | 5480 | 156940 | 2355140 | 348843.5 | 200648 | 200648 | 7.244193 |
| Sep-12 | 2880724 | 349000 | 732 | 1 | -101780 | 0 | 39056 | 64108 | 1384 | 144020 | 2209170 | 379223.4 | 191366 | 191366 | 8.254222 |
| Aug-12 | 2328670 | 360520 | 800 | 1 | -87159 | 0 | 40096 | 65714 | 18651 | 120000 | 1979976 | 354571.4 | 173124 | 173124 | 6.459198 |
| Jul-12 | 2392468 | 369240 | 826 | 1 | -88757 | 0 | 42512 | 66286 | 20041 | 123900 | 2027866 | 369240 | 177873 | 177873 | 6.479438 |
| Jun-12 | 2472767 | 378780 | 990 | 1 | -87057 | 0 | 43152 | 68618 | 24713 | 148500 | 2080260 | 372833.2 | 183841 | 183841 | 6.52824 |
| Jun-12 | 1178139 | 181140 | 980 | 1 | -38573 | 0 | 20656 | 33088 | 15171 | 63210 | 994820.9 | 178296.1 | 87605 | 87605 | 6.504024 |
| May-12 | 2393834 | 390880 | 990 | 1 | -86003 | 0 | 45648 | 71126 | 30771 | 148500 | 2146713 | 214671.3 | 177846 | 177846 | 6.124218 |

Except for September 12, the tariff is optimized. During Sept bill “Debit bill adjustment” of Rs. 310617.27 is added to bill which has increased rate / kwh. Apart from seasonal changes, monthly Kwh show steady trend.

Floor Level Loading

| Floor Level running KW | |
|------------------------|----------------|
| Work Area HVAC | 263.39 |
| Raw power | 15.629 |
| Work area Lighting | 43.955 |
| Workstation DB | 79.73 |
| Server DB | 51.685 |
| Data center AC | 57.706 |
| Data center UPS DB | 81.782 |
| Total | 593.877 |



It can be noticed from above that work area lighting load is approximately $44/0.85 = 51.76$ KW. Entire lighting works on UPS output and average UPS efficiency is 85%. Actual lighting load is

44KW, whereas at UPS input it becomes 52KW. Day and night lighting load is almost same. This means 8KW x 24 hours x 300 days = 57600 KWh are spent extra costing you almost Rs.3.5 Lacs annually due to lights working on UPS.

Yet another data collection shows that workstation area UPS are loaded at 185KW during day and 129 KW during night. 44KW lighting load and 52KW server load may be ON during night which works on these UPS. Rest of the 33KW load must be contributed by workstations. In terms of workstations, this is load of around 400 workstations. It will be worth verifying this server and workstation load and it's utility during night. These servers contribute to 292000Kwh and Workstations contribute 185000Kwh during night. Present contribution of this load is Rs.31 Lacs annually.

Summary of Electrical Power Quality Parameters at Critical IT feeders

| Combination of 5 x 200KVA UPS | | | | | | |
|--|-------------|----------------|----------------------|----------------------|-------------|-------|
| UPS Tag | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| UPS-1 | 231.7 | 49.89 | 0.92 | 39.43 | 62.25 | 36.24 |
| UPS-2 | 230.9 | 49.89 | 0.95 | 39.33 | 61.91 | 35.63 |
| UPS-3 | 231.7 | 49.89 | 0.98 | 41.22 | 71.83 | 41.56 |
| UPS-4 | 231.68 | 49.89 | 1.05 | 72.95 | 73.03 | 39.24 |
| UPS-5 | 231.71 | 49.89 | 1.17 | 60.83 | 85.77 | 42.15 |
| | | | | | | |
| | | | | | | |
| Combination of 2 x 200KVA UPS - server | | | | | | |
| UPS Tag | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| UPS-A | 232.21 | 50.04 | 0.86 | 13.56 | 61.36 | 38.47 |
| UPS-B | 229.47 | 50.04 | 0.74 | 15.07 | 74.93 | 45 |
| | | | | | | |

This setup is equipped with 7 numbers of 200 KVA UPS systems. They are arranged in two groups.

- 1) 5 x 200 KVA work in parallel redundant mode and supply to floor level workstations, floor level servers and work area lighting.
- 2) 2 x 200 KVA work independently and work as dual source for data center.

Above data is recorded at UPS output terminals while supplying normal load. All UPS systems appear to deliver acceptable power quality to all critical loads.

| Power Quality at Floor Level Server DBs | | | | | | | |
|---|----------|-------------|----------------|----------------------|----------------------|-------------|-------|
| Floor | Location | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| A1 | DB-1 | 229.99 | 49.88 | 1.59 | 93.66 | 2.11 | 0.769 |
| | DB-2 | 230.00 | 49.88 | 1.59 | 41.31 | 14.07 | 3.61 |
| A2 | DB-1 | 230.12 | 49.88 | 1.89 | 65.69 | 8.01 | 2.88 |
| | DB-2 | 230.27 | 49.88 | 1.87 | 21.32 | 1.3 | 0.192 |
| A3 | DB-1 | 229.71 | 49.89 | 2.46 | 26.7 | 7.32 | 1.51 |
| | DB-2 | 229.39 | 49.88 | 2.14 | 19.16 | 1.46 | 0.258 |
| A4 | DB-1 | 229.95 | 49.88 | 2.3 | 45.04 | 2.65 | 0.477 |
| A5 | DB-1 | 229.98 | 49.88 | 1.83 | 82.91 | 2.59 | 0.732 |
| | DB-2 | 229.57 | 49.88 | 1.8 | 17.77 | 1.08 | 0.166 |
| A6 | DB-1 | 229.69 | 49.88 | 2.27 | 60.26 | 23.16 | 12.43 |
| | DB-2 | 229.69 | 49.88 | 2.32 | 60.59 | 6.22 | 2.11 |
| Admin | DB-1 | 231.17 | 49.88 | 5.18 | 17.29 | 0.371 | 0.043 |
| | DB-2 | 230.36 | 49.88 | 5.23 | 50.02 | 1.08 | 0.252 |

Above table shows that power quality parameters for output power available at respective floor DBs is well within limit and clean power is available for the critical loads. As shown voltage distortion for Admin DBs is on higher side and needs investigation.

| Power Quality at Floor Level Server DBs | | | | | | | |
|---|----------|-------------|----------------|----------------------|----------------------|-------------|-------|
| Floor | Location | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| B0 | DB-1 | 230.19 | 49.88 | 1.56 | 16.33 | 1.46 | 0.404 |
| | DB-2 | 229.17 | 49.88 | 1.54 | 14.93 | 0.84 | 0.184 |
| B2 | DB-1 | 229.99 | 49.89 | 2.3 | 16.61 | 3.03 | 0.813 |
| | DB-2 | 229.82 | 49.88 | 2.3 | 60.45 | 6.17 | 1.78 |
| B3 | DB-1 | 229.98 | 49.88 | 2.73 | 12.73 | 0.797 | 0.173 |
| | DB-2 | 229.57 | 49.88 | 2.74 | 12.96 | 0.705 | 0.152 |
| B4 | DB-1 | 230.12 | 49.88 | 2.6 | 17.99 | 21.77 | 9.61 |
| | DB-2 | 230.27 | 49.88 | 2.63 | 14.19 | 0.91 | 0.176 |
| B5 | DB-1 | 230.21 | 49.88 | 2.26 | 21.74 | 12.2 | 3.12 |
| | DB-2 | 229.96 | 49.89 | 2.27 | 41.94 | 0.78 | 0.266 |
| B6 | DB-1 | 229.86 | 49.88 | 2.44 | 92.63 | 1.23 | 0.251 |
| | DB-2 | 230.05 | 49.88 | 2.19 | 53.46 | 11.04 | 3.13 |

Above table shows that power quality parameters for output power available at respective floor DBs is well within limit and clean power is available for the critical loads.

| Power Quality at Floor Level Server DBs | | | | | | | |
|---|----------|-------------|----------------|----------------------|----------------------|-------------|-------|
| Floor | Location | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| D0 | DB-1 | 230.21 | 49.88 | 1.8 | 41.84 | 0.97 | 0.276 |
| | DB-2 | 229.96 | 49.88 | 1.71 | 36.31 | 1.15 | 0.411 |
| D1 | DB-1 | 229.93 | 49.88 | 5.24 | 36.57 | 0.95 | 0.405 |
| D2 | DB-1 | 231.17 | 49.88 | 2.79 | 19.99 | 1.24 | 0.23 |
| | DB-2 | 230.36 | 49.88 | 2.81 | 21.96 | 0.9 | 0.143 |
| D3 | DB-1 | 229.96 | 49.89 | 0.94 | 37.12 | 2.2 | 0.853 |
| | DB-2 | 229.84 | 49.88 | 0.964 | 43.62 | 2.01 | 0.755 |
| D4 | DB-1 | 229.73 | 49.89 | 2.63 | 19.9 | 2.32 | 0.508 |
| | DB-2 | 230.15 | 49.88 | 2.63 | 4.37 | 23.06 | 0.241 |
| E0 | DB-1 | 230.87 | 49.88 | 0.9 | 35.67 | 1.15 | 0.413 |

Above table shows that power quality parameters for output power available at respective floor DBs is well within limit and clean power is available for the critical loads.

| Power Quality at Floor Level workstation DBs | | | | | | | |
|--|----------|-------------|----------------|----------------------|----------------------|-------------|-------|
| Floor | Location | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| A1 | DB-1 | 230.01 | 49.89 | 1.61 | 101.66 | 5.71 | 2.42 |
| | DB-2 | 230.36 | 49.88 | 1.59 | 106.28 | 2.23 | 0.94 |
| A2 | DB-1 | 229.96 | 49.88 | 1.9 | 78.85 | 4.85 | 2.21 |
| | DB-2 | 230.27 | 49.88 | 1.89 | 79.64 | 5.28 | 2.87 |
| A3 | DB-1 | 229.71 | 49.88 | 2.13 | 80.75 | 6.36 | 2.85 |
| | DB-2 | 230.37 | 49.88 | 2.13 | 61.06 | 6.63 | 2.47 |
| A4 | DB-1 | 229.82 | 49.88 | 2.29 | 95.83 | 9.09 | 3.22 |
| | DB-2 | 229.39 | 49.88 | 2.29 | 87.42 | 8.51 | 3.99 |
| A5 | DB-1 | 230.36 | 49.88 | 1.84 | 78.81 | 5.39 | 2.16 |
| | DB-2 | 229.86 | 49.88 | 1.81 | 79.26 | 4.22 | 0.98 |
| A6 | DB-1 | 230.05 | 49.88 | 2.2 | 72.99 | 6.57 | 2.95 |
| | DB-2 | 229.42 | 49.88 | 2.24 | 76.49 | 7.28 | 2.55 |
| Admin | DB-1 | 230.53 | 49.88 | 5.15 | 91.45 | 2.22 | 0.911 |
| | DB-2 | 230.36 | 49.88 | 5.15 | 96.45 | 1.98 | 0.669 |

Above table shows that power quality parameters for output power available at respective floor DBs is well within limit and clean power is available for the critical loads. As shown voltage distortion for Admin DBs is on higher side and needs investigation.

| Power Quality at Floor Level workstation DBs | | | | | | | |
|--|------|-------------|----------------|----------------------|----------------------|-------------|------|
| Floor | | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| B0 | DB-1 | 230.21 | 49.89 | 1.54 | 70.61 | 3.82 | 1.46 |
| | DB-2 | 229.86 | 49.88 | 1.54 | 77.98 | 3.6 | 1.4 |
| B2 | DB-1 | 229.82 | 49.88 | 2.28 | 78.4 | 7.55 | 3.3 |
| | DB-2 | 230.14 | 49.88 | 2.28 | 78.6 | 5.63 | 2.83 |
| B3 | DB-1 | 229.34 | 49.88 | 2.73 | 68.7 | 7.43 | 3.38 |
| B4 | DB-1 | 230.36 | 49.88 | 2.55 | 74.04 | 6.72 | 2.85 |
| | DB-2 | 229.96 | 49.88 | 2.58 | 73.23 | 4.32 | 1.97 |
| B5 | DB-1 | 231.17 | 49.89 | 2.26 | 74.96 | 4.53 | 1.8 |
| | DB-2 | 230.36 | 49.88 | 2.27 | 61.75 | 2.93 | 1.43 |
| B6 | DB-1 | 230.27 | 49.88 | 1.53 | 82.24 | 6.78 | 3.51 |
| | DB-2 | 229.71 | 49.88 | 1.63 | 75.17 | 7.53 | 3.55 |

Above table shows that power quality parameters for output power available at respective floor DBs is well within limit and clean power is available for the critical loads.

| Power Quality at Floor Level workstation DBs | | | | | | | |
|--|----------|-------------|----------------|----------------------|----------------------|-------------|-------|
| Floor | Location | Voltage (V) | Frequency (Hz) | % Voltage Distortion | % Current Distortion | Current (A) | KW |
| D0 | DB-1 | 230.45 | 49.88 | 1.24 | 110.83 | 3.76 | 1.26 |
| | DB-2 | 229.82 | 49.88 | 1.79 | 92.9 | 3.34 | 1.01 |
| D1 | DB-1 | 229.53 | 49.88 | 4.42 | 70.12 | 5.4 | 2.41 |
| | DB-2 | 230.12 | 49.88 | 4.52 | 79.14 | 6.39 | 2.71 |
| D2 | DB-1 | 229.64 | 49.88 | 2.83 | 75.59 | 2.64 | 0.604 |
| | DB-2 | 229.86 | 49.88 | 2.83 | 90.91 | 3.94 | 1.03 |
| D3 | DB-1 | 230.05 | 49.88 | 0.96 | 75.76 | 5.14 | 2.16 |
| | DB-2 | 230.21 | 49.89 | 0.97 | 73.48 | 2.83 | 1.28 |
| D4 | DB-1 | 230.27 | 49.88 | 2.66 | 74.9 | 1.21 | 0.393 |
| | DB-2 | 229.71 | 49.88 | 4.37 | 90.26 | 4.73 | 1.38 |

Above table shows that power quality parameters for output power available at respective floor DBs is well within limit and clean power is available for the critical loads. As shown voltage distortion for D4 DB - 2 is on higher side and needs investigation.

UPS performance and efficiency analysis.

UPS arrangement and loading

UPS Group 1

At present only 3 systems are working.

5 x 200 KVA UPS are located in basement UPS room. Batteries are arranged in a separate room near UPS room. **At present loading, this room receives almost 25KW heat load (Input – Output as above) released by these UPS systems.**

5 x 200 KVA UPS Parallel combination receives input from either of the transformers. The output is taken to respective floors through bus raisers A,B and D,E.

Each level has a HVAC/Electrical Gallery, which selects the source from these raisers through automatic switch and further distributes it for Lighting, Floor Server and workstations.

UPS Group 2

At present both the systems are working.

2 x 200 KVA UPS are located on Datacenter floor and serve as dual power source for data center equipment. The load on these UPS is 83KW. **At this loading, the UPS room receives almost 13 KW heat load released by these UPS systems.**

Day / Night UPS loading on UPS and corresponding loss as per recorded data.

| | | | |
|---------------------------------------|--------|--------|-------|
| Total UPS power required – Day time | | | |
| | Input | Output | Loss |
| Total | 306.48 | 268.97 | 37.51 |
| Total UPS power required - Night time | | | |
| Total | 251.47 | 212.75 | 38.72 |

This indicates that about 3Lacs Kwh or Rs.20 Lacs are spent annually on generating clean / uninterrupted electrical power for IT load.

UPS Performance Analysis

| Location | Data Center Load 2 x 200KVA | | | | | |
|---|-----------------------------|------------|------------|--|--|--|
| | UPS Input | UPS Output | efficiency | | | |
| A1 | 44.83 | 38 | 0.85 | | | |
| B1 | 51.45 | 45 | 0.87 | | | |
| Total | 96.28 | 83 | | | | |
| | Total Loss for 24 hours | 13.28 | | | | |
| As shown above data center UPS work with 85% efficiency and total loss is about 13KW. With higher efficiency UPS configuration there is possibility of saving 9KW. On yearly basis this amounts to savings of Rs. 5 Lacs at present tariff. | | | | | | |
| | | | | | | |

| Location | Combination of 3 UPS 3 x 200KVA Parallel | | | | | |
|-----------------|---|---------------|-------------|---------------|---------------|-------------|
| UPS | Day | | | Night | | |
| | Input | Output | Efficiency | Input | Output | Efficiency |
| 1 | 67.33 | 59.44 | 0.88 | 50.06 | 42 | 0.84 |
| 4 | 72.57 | 63.68 | 0.88 | 53 | 45.15 | 0.85 |
| 5 | 70.3 | 62.85 | 0.89 | 52.12 | 42.6 | 0.82 |
| Total | 210.2 | 185.97 | 0.88 | 155.19 | 129.75 | 0.84 |
| | Total Loss during day | | 24.23 | | | |
| | Total Loss during night | | 25.435 | | | |

As shown above work station UPS work with 85% (average) efficiency and total loss is about 25KW. With higher efficiency UPS configuration there is possibility of saving 15 KW. On yearly basis this amounts to savings of Rs. 8.5 Lacs at present tariff.

| | |
|--|-------------------|
| 1st Year savings in energy cost | 1350000.00 |
| 2nd year savings in energy cost | 1485000.00 |
| 1 year AMC cost of old UPS systems | 700000.00 |
| Cost of harmonic filters | 1000000.00 |
| Scrap Value of Old UPS | 2000000.00 |
| Total Savings Possible in 2 years | 5535000.00 |

Salvage value of OLD UPS can be almost double if they are auctioned.

EARTHLING TEST RESULTS

All electrical distribution panels were tested for proper earthing. More than 180 locations were tested for earth resistance. Following results were not satisfactory. At some places earth strip accessibility was not suitable for tester in use.

| Location | Earth Resistance in Ohms |
|------------------------------------|--------------------------|
| Data Center PDU B2 | OPEN |
| E0 -VRV Panel | OPEN |
| D4 -Main UPS DB | OPEN |
| D4- VRV Panel | OPEN |
| core 3 stilt panel room all Panels | OPEN |
| C Building Main UPS DB | OPEN |
| B1 VRV DB | OPEN |
| B4 UPS DB | OPEN |
| A1 VRV DB | OPEN |
| A4 VRV DB | OPEN |
| APFC Panel MLTP-2 | OPEN |
| E0- LDB | Not Accessible |
| E0- UPS DB | Not Accessible |
| C BUILDING VRV DB | Not Accessible |
| A6 Main common DB | Not Accessible |

It is advised that above situations should be rectified. At rest of the places the earthing resistance was satisfactory.

Average area wise Lux Measurement.

In following areas the illumination level was found to be extremely Low. We are not aware of any standard being followed at ABC regarding illumination levels. In general the illumination levels are on lower side throughout the work areas. However following is a list of areas with identifiers, where the same was found to be extremely low. Detail area wise measurement is included elsewhere in this report.

| LUX LEVEL REPORT | | | | | | |
|--|----|----|----|---|------|--------|
| Cubicle No | 1 | 2 | 3 | 4 | Avg. | Remark |
| A Building 1st Floor Workstation Area | | | | | | |
| 6 | 57 | | | | 57 | Low |
| 10 | 68 | | | | 68 | Low |
| 13 | 63 | | | | 63 | Low |
| 24 | 95 | | | | 95 | Low |
| Cabin 2 | 57 | | | | 57 | Low |
| A Building 2nd Floor Workstation Area | | | | | | |
| 1 | 90 | | | | 90 | Low |
| 30 | 95 | | | | 95 | Low |
| TL2 | 92 | | | | 92 | Low |
| A Building 3rd Floor Workstation Area | | | | | | |
| 2 | 97 | | | | 97 | Low |
| 24 | 75 | | | | 75 | Low |
| 25 | | 99 | | | 99 | Low |
| Cabin 2 | 93 | | | | 93 | Low |
| A Building 4th Floor Workstation Area | | | | | | |
| Cabin 1 | 68 | | | | 68 | Low |
| Cabin 2 | 73 | | | | 73 | Low |
| A Building 5th Floor Workstation Area | | | | | | |
| 12 | | | 77 | | 77 | Low |
| 16 | | 95 | | | 95 | Low |
| 21 | 82 | | | | 82 | Low |
| 25 | 95 | | | | 95 | Low |
| Cabin 2 | 56 | | | | 56 | Low |
| Disc 2 | | 87 | | | 87 | Low |
| Small Conff 1 | | 80 | | | 80 | Low |
| B Building 0th Floor Workstation Area | | | | | | |
| 9 | 80 | | | | 80 | Low |
| 12 | 93 | | | | 93 | Low |
| 14 | 98 | | | | 98 | Low |
| Cabin 1 | 93 | | | | 93 | Low |
| B Building 1st Floor Workstation Area | | | | | | |
| 7 | 48 | | | | 48 | Low |
| 11 | 98 | | | | 98 | Low |

| | | | | | | |
|--|--|--|--|--|--|--|
| | | | | | | |
|--|--|--|--|--|--|--|

| LUX LEVEL REPORT | | | | | | |
|--|------------|---------------|---|---|------|--------|
| Cubicle No | 1 | 2 | 3 | 4 | Avg. | Remark |
| B Building 2nd Floor Workstation Area | | | | | | |
| 29 | 92 | | | | 92 | Low |
| B Building 3rd Floor Workstation Area | | | | | | |
| 1 | 87 | | | | 87 | Low |
| B Building 4th Floor Workstation Area | | | | | | |
| 8 | 98 | | | | 98 | Low |
| 21 | 52 | | | | 52 | Low |
| 28 | 84 | | | | 84 | Low |
| Cabin 2 | 95 | | | | 95 | Low |
| B Building 5th Floor Workstation Area | | | | | | |
| 10 | 75 | 98 | | | 86 | Low |
| 27 | | 93 | | | 93 | Low |
| TL5 | | 81 | | | 81 | Low |
| Cabin 2 | 77 | | | | 77 | Low |
| B Building 6th Floor Workstation Area | | | | | | |
| 25 | 74 | | | | 74 | Low |
| D Building 1st Floor Workstation Area | | | | | | |
| 3 | | 89 | | | 89 | Low |
| 4 | 73 | | | | 73 | Low |
| 25 | 98 | | | | 98 | Low |
| Small Conff 1 | 99 | | | | 99 | Low |
| D Building 2nd Floor Workstation Area | | | | | | |
| 15 | 97 | | | | 97 | Low |
| 25 | 97 | | | | 97 | Low |
| Cabin 1 | 97 | | | | 97 | Low |
| Small Conff 1 | 89 | | | | 89 | Low |
| D Building 3rd Floor Workstation Area | | | | | | |
| 9 | 55 | | | | 55 | Low |
| TL6 | 97 | | | | 97 | Low |
| Small Conff 2 | | 84 | | | 84 | Low |
| D Building 4th Floor Workstation Area | | | | | | |
| 9 | | 87 | | | 87 | Low |
| 14 | 97 | | | | 97 | Low |
| Big Conff 1 | 97 | | | | 97 | Low |
| C0 | LUX | Remark | | | | |
| Garnet | 89 | Low | | | | |
| Admin office | 81 | Low | | | | |

The work area illumination power requirement is about 44KW or 7% of total consumption. At present you are spending 15% extra over this by connecting this load to UPS output. You can spend this 15% extra on illumination without increasing total energy requirement and generate more illumination by connecting this load directly to utility supply.

Infrared Thermography test results

Infrared thermography was carried out on all working electrical LT side feeders while they were carrying normal current. Following are few alarming observations. Audit team had identified these and other thermographed feeders where some corrective action was required by sticking stickers.

| | | |
|---------------------------------------|-----------------------------------|------------------------|
| MLTP - 1 - APFC Panel | | |
| Tag | Nature of Fault - hot spot | Required action |
| 5F3 50 KVAR - Y phase | Cable loose - 58.4 C | Needs tightening |
| 5F2 50 KVAR - B phase | Cable loose - 58.8 C | Needs tightening |
| APFC Feeder - Y & B phase | Cable loose in lug - 52.3 C | Needs tightening |
| MLTP - 2 - APFC Panel | | |
| Tag | Nature of Fault - hot spot | Required action |
| Main incomer - R & Y phase | Cable loose in lug - 93.5 C | Needs tightening |
| Main incomer - load side - R phase | Busbar loose in bolt-65.5C | Needs tightening |
| F-8 Contactor - all cables | Cable loose - 46.4 C | Needs tightening |
| F-6 contactor - Y & B phase | Cable loose - 93.7 C | Needs tightening |
| 3rd floor - Data center | | |
| Tag | Nature of Fault - hot spot | Required action |
| PDU - B1 - Cable no. R4 & R10 | Cable loose - 53.4 C | Needs tightening |
| Server UPS Room - AC Panel - 2 | | |
| Tag | Nature of Fault - hot spot | Required action |
| 3F5 - MCCB - R phase | Cable loose in lug - 63.3 C | Needs tightening |
| 3F5 - MCCB - bus R phase | Cable loose in lug - 70.4 C | Needs tightening |
| D - 0th floor | | |
| Tag | Nature of Fault - hot spot | Required action |
| Server DB -2 - MCB R phase | Cable loose - 50.9 C | Needs tightening |
| A - 0th floor | | |
| Tag | Nature of Fault - hot spot | Required action |
| UPS DB -2 - MCB Neutral | Cable loose - 214.7 C | Needs tightening |
| B - 2th floor | | |
| Tag | Nature of Fault - hot spot | Required action |
| UPS DB -2 - MCB Y phase | Cable loose - 72 C | Needs tightening |
| A - 4th floor | | |
| Tag | Nature of Fault - hot spot | Required action |
| VRV Panel - MCCB - R phase | Cable loose in lug - 50.3 C | Needs tightening |
| B - 5th floor | | |
| Tag | Nature of Fault - hot spot | Required action |
| VRV DB - B phase | Cable loose - 44 C | Needs tightening |
| | | |

| | | |
|----------------------------|-----------------------------------|------------------------|
| A - 5th floor | | |
| Tag | Nature of Fault - hot spot | Required action |
| UPS DB -1 MCB - B phase | Cable loose - 45.4 C | Needs tightening |
| Auditorium | | |
| Tag | Nature of Fault - hot spot | Required action |
| AHU Panel - MCCB - Y phase | Busbar loose in bolt-42.5 C | Needs tightening |

-----END OF ENERGY AUDIT REPORT-----